

WATER WELL REPORT

Start Card No. W 109516
 Unique Well I.D. # AEM568
 Water Right Permit No.

STATE OF WASHINGTON

(1) OWNER: Name RAYBURN, PHIL D. & CHERYL Address 206 EASTRIDGE DR. EAST WENATCHEE, WA 98802-

(2) LOCATION OF WELL: County DOUGLAS - NE 1/4 SE 1/4 Sec 12 T 24 N., R 21 WM
 (2a) STREET ADDRESS OF WELL (or nearest address) 443 ROUD CYN. RD., EAST WENATCHEE

(3) PROPOSED USE: DOMESTIC

(10) WELL LOG

(4) TYPE OF WORK: Owner's Number of well (If more than one) Method: ROTARY
 NEW WELL

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

(5) DIMENSIONS: Diameter of well 6 inches
 Drilled 605 ft. Depth of completed well 605 ft.

(6) CONSTRUCTION DETAILS:
 Casing installed: 6 " Dia. from +1.5 ft. to 18 ft.
 WELDED /NO SHOE " Dia. from ft. to ft.
 " Dia. from ft. to ft.

MATERIAL	FROM	TO
BROWN BASALT	0	41
BLACK BASALT	41	142
HARD BLACK BASALT	142	204
BROWN FRACTURED BASALT	204	214
HARD BLACK BASALT	214	340
BLACK CLAY	340	346
DARK GRAY CLAY WOOD	346	353
DARK GRAY CLAY	353	367
BLACK BASALT	367	440
BROKEN BASALT CLAY	440	444
GRAY CLAY BASALT WOOD	444	457
DARK BROWN CLAY	457	479
YELLOW CLAY	479	516
DARK BROWN CLAY	516	519
BROKEN BASALT CLAY	519	522
BASALT	522	601
CAVING BROKEN BASALT	601	606

Perforations: NO
 Type of perforator used
 SIZE of perforations in. by in.
 perforations from ft. to ft.
 perforations from ft. to ft.

Screens: NO
 Manufacturer's Name
 Type Model No.
 Diam. slot size from ft. to ft.
 Diam. slot size from ft. to ft.

Gravel packed: NO
 Gravel placed from ft. to ft. Size of gravel ft.

Surface seal: YES To what depth? 18 ft.
 Material used in seal BENTONITE
 Did any strata contain unusable water? NO
 Type of water? Depth of strata ft.
 Method of sealing strata off SEAL METHOD 1

(7) PUMP: Manufacturer's Name Type SUBMERSIBLE H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.
 Static level NONE ft. below top of well Date 08/26/98
 Artesian Pressure lbs. per square inch Date
 Artesian water controlled by CAP

Work started 08/19/98 Completed 08/26/98

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.
 Was a pump test made? NO If yes, by whom?
 Yield: gal./min with ft. drawdown after hrs.

WELL CONSTRUCTOR CERTIFICATION:
 I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

Recovery data
 Time Water Level Time Water Level

NAME TUNNADY DRILLING, INC.
 (Person, firm, or corporation) (Type or print)

Date of test / /
 Bailer test gal/min. ft. drawdown after hrs.
 Air test 0 gal/min. w/ stem set at 605 ft. for hrs.
 Artesian flow g.p.m. Date
 Temperature of water Was a chemical analysis made? NO

ADDRESS P.O. BOX 77
 [SIGNED] License No. 1249
 Contractor's Registration No. TUNNADY 1330 C Date 08/27/98

THE DEPARTMENT OF ECOLOGY DOES NOT GUARANTEE THE DATA OR THE INFORMATION ON THIS WELL REPORT.