

# WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W 48762

UNIQUE WELL I.D. # AAJ 609

Water Right Permit No. \_\_\_\_\_

(1) OWNER: Name Rex PITZINGER Address Entiat

LOCATION OF WELL: County Chelan NW 1/4 NW 1/4 Sec 19 T26 N, R 20 W

(2a) STREET ADDRESS OF WELL (or nearest address) Entiat Valley 1/2 mi W. Ardenvoor

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐  
☐ Irrigation ☐ Test Well ☐ Other ☐  
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) \_\_\_\_\_  
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐  
Deepened ☐ Cable ☐ Driven ☐  
Reconditioned ☐ Rotary ☐ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 40 feet. Depth of completed well 40 ft.

(6) CONSTRUCTION DETAILS:  
Casing installed: 6 ft. Diam. from -2 ft. to 40 ft.  
Welded ☒ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Liner installed ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded ☐ Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes ☐ No ☒  
Type of perforator used \_\_\_\_\_  
SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes ☐ No ☒  
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No. \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes ☐ No ☒ Size of gravel \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes ☒ No ☐ To what depth? 18 ft ft.  
Material used in seal Bentonite  
Did any strata contain unusable water? Yes ☐ No ☒  
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation above mean sea level 1000  
Static level 22 ft. below top of well Date 8-17-96  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made? Yes ☐ No ☒ If yes, by whom? \_\_\_\_\_  
Yield: \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)  
Time Water Level Time Water Level Time Water Level

Date of test \_\_\_\_\_  
Boiler test \_\_\_\_\_ gal./min. with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Airstest 20 gal./min. with stem set at \_\_\_\_\_ ft. for \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes ☐ No ☒

## (10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
over garden	0	12
Gravel w/ clay binder	12	24
Cobbles & Sand	24	42

Work Started 8-17-96 Completed 8-17-96

## WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME GARDNER DRILLING  
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address RT 2 Box 409 Chelan

(Signed) [Signature] License No. 12412  
(WELL DRILLER)

Contractor's Registration No. \_\_\_\_\_ Date 8-17-96

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.