

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. W 087140
Unique Well I.D. # ACK059
Water Right Permit No.

57184

(1) OWNER: Name WILCOX, GARY Address 1602 GOLDAU RD. E TACOMA, WA 98424-

(2) LOCATION OF WELL: County DOUGLAS - SE 1/4 NE 1/4 Sec 15 T 24 N., R 21E WM

(2a) STREET ADDRESS OF WELL (or nearest address) 3 SW / T.5 BADGER MT., EAST WENATCHEE H

(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well
(If more than one)
NEW WELL Method: ROTARY

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 178 ft. Depth of completed well 178 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Dia. from +1.5 ft. to 18.5 ft.
WELDED / NO SHOULDER " Dia. from ft. to ft.
" Dia. from ft. to ft.

Perforations: NO

Type of perforator used
SIZE of perforations
perforations from ft. to ft. in. by in.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: NO

Manufacturer's Name
Type Model No.
Diam. slot size from ft. to ft.
Diam. slot size from ft. to ft.

Gravel packed: NO

Gravel placed from ft. to ft. Size of gravel
ft.

Surface seal: YES

To what depth? 18 ft.
Material used in seal BENTONITE
Did any strata contain unusable water? NO
Type of water? Depth of strata ft.
Method of sealing strata off SEAL METHOD 1

(7) PUMP: Manufacturer's Name
Type SUBMERSIBLE H.P.

(8) WATER LEVELS: Land-surface elevation
above mean sea level ... ft.
Static level 0 ft. below top of well Date 06/23/97
Artesian Pressure lbs. per square inch Date
Artesian water controlled by CAP

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?
Yield: gal./min with ft. drawdown after hrs.

Recovery data

Time Water Level Time Water Level Time Water Level

Date of test / /
Bailer test gal./min. ft. drawdown after hrs.
Air test 0 gal./min. w/ stem set at 197 ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
BLACK TOPSOIL	0	6
BROWN BASALT	6	12
BROWN BASALT	12	17
HARD BLACK BASALT	17	178

Work started 06/23/97

Completed 06/23/97

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME TOMMATER DRILLING, INC.

(Person, firm, or corporation) (Type or print)

ADDRESS P.O. BOX 777 LEAVENWORTH

[SIGNED] *[Signature]* license No. 1249

Contractor's
Registration No. TOWARDI 1330 C Date 06/24/97